CENTRO DI RICERCA E SPERIMENTAZIONE
PER L'INDUSTRIA CERAMICA

Bologna, 10/12/2018

FRIANOVO CERAMIC
FACTORY LLC
141147, Russia, MR,
Shelkovsky Distr.

TEST LABORATORY

TEST REPORT No. 7761/18

Requested by:	FRIANOVO CERAMIC FACTORY LLC 141147, Russia, MR, Shelkovsky Distr.
On (date):	19/10/18
For the sample marked:	"URBAN".

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision.

The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 3 pages this cover included.

Via Martelli 26
40138 Bologna – Italy
Tel. +39 051 534015
Fax +39 051 530085
Part. IVA 0094778-0375

centro.ceramico@centroceramico.it
www.centroceramico.it

Viale Valle d'Aosta 1
41049 Sassuolo (MO) – Italy
Tel. +39 0536 802154
Fax +39 0536 800662

Description of the sample:	Glazed ceramic tiles 60 x 60 x 1.1 cm marked "URBAN".
Manufacturer:	----------
Sampling details	
- Where:	----------
- Date:	----------
- By whom:	CUSTOMER
- How (methods):	----------
Date of receipt in laboratory:	05/11/18

TESTS PERFORMED :

			Date of starting	Date of ending
X	DIN 51130 (06/2004)	Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test	04/12/18	04/12/18

DIN 51130 (06/2004)- Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test

Surface characteristics

- [ ] Smooth
- [ ] Profiled
- [ ] Structured
- [X] Rough

OPERATIVE CONDITIONS

Fixing scheme



RESULTS

Average total acceptance angle:	**14.2°**
Movement area (cm^3/dm^2):	---

CLASSIFICATION (BGR 181- 10/2003)

Group of anti - slip properties:	**R10**
Movement area evaluation group:	---

Pietro Bruzzi
Technical verification

Centro Ricerca Specializzazione per l' Industria Ceramica - CENTRO CERAMICO BOLOGNA

Prof. Maria Chiara Bignozzi
Director