



CENTRO DI RICERCA E SPERIMENTAZIONE
PER L'INDUSTRIA CERAMICA

Bologna, 10/12/2018

*FRIANOVO CERAMIC
FACTORY LLC
141147, Russia, MR,
Shelkovsky Distr.*

TEST LABORATORY

TEST REPORT No. 7758/18

Requested by:	FRIANOVO CERAMIC FACTORY LLC 141147, Russia, MR, Shelkovsky Distr.
On (date):	19/10/18
For the sample marked:	"POLARIS".

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision.

**The reproduction of this test report is only authorized in the form of a complete photographic facsimile.
Our written approval is necessary for any partial reproduction.**

This test report consists of 3 pages this cover included.



Description of the sample:	Glazed ceramic tiles 30 x 60 x 0.9 cm marked "POLARIS".
Manufacturer:	-----
Sampling details	
- Where:	-----
- Date:	-----
- By whom:	CUSTOMER
- How (methods):	-----
Date of receipt in laboratory:	05/11/18

TESTS PERFORMED :

			Date of starting	Date of ending
<input checked="" type="checkbox"/>	DIN 51130 (06/2004)	Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test	04/12/18	04/12/18




DIN 51130 (06/2004)- Determination of the anti - slip properties – Workrooms and fields of activities with raised slip danger, walking method – ramp test

Surface characteristics

- Smooth
- Profiled
- Structured
- Rough

OPERATIVE CONDITIONS

Fixing scheme



RESULTS

Average total acceptance angle:

13.5°

Movement area (cm³/dm²):

CLASSIFICATION (BGR 181- 10/2003)

Group of anti - slip properties:

R10

Movement area evaluation group:

Pietro Bruzzi
Technical verification



Prof. Maria Chiara Bignozzi

Director